

MINUTES OF THE FRANKLIN WATER COMMISSIONERS
MONDAY, October 27, 2014 @ 11:30 A.M.
Field Meeting: Monday, October 27, 2014; 11:30 am

Members present: Jess Alexant and Marshall Ploof.

Guest: Brent Desranleau

Jes Alexant, Chairman of the Town of Franklin Water Commission, met with Marshall Ploof of the Franklin Fire District and inspected the spring water supply storage tank facilities. Brent J. Desranleau of the Vermont Water Rural Association participated in the meeting.

Marshall opened the covers to the junction / overflow vaults and the storage tank vaults. Neither the primary overflow nor the tank were overflowing. The water in both storage tank compartments was 9.2 feet deep, per visual observation of the dedicated depth rulers. The clarity of the water was good. Tank interior wall surfaces which were visible nearby appeared in good condition. The valves appeared to be in good condition.

Jes climbed down the stairs into the storage tank valve chamber, and noted the two installed chemical metering pumps. Neither pump was operating during the visit.

Brent noted that the Vermont Rural Water Association had funding programs available.

Jes took several photos during the visit.

Meeting adjourned at 12:30 p.m.

Respectively,
Jess Alexant
October 27, 2014

These minutes are not official until approved at the Water Commissions next regular meeting.